



This Part requires four clamps, part number 128-300.
See additional drawing for information on these clamps.

NOTES:
-SOME HIDDEN LINES NOT SHOWN
-BREAK ALL SHARP CORNERS
-REPORT ALL CHANGES TO ENGINEERING

PROPRIETARY AND CONFIDENTIAL
THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF FERNCO, INC. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF FERNCO, INC. IS PROHIBITED.



Part Weight	8.185 lbs.	TOLERANCES: .X= Fractional ± .XX= ±.02 .XXX= ±.030 ANG.= ±0.5° UNLESS OTHERWISE SPECIFIED	DESCRIPTION:	
Min/Max Temp.	-30/140 Degrees F		Coupling 12" Concrete x 12" Concrete	
Pressure Tested	4.3 PSI	UNITS: INCHES SIZE A 3RD ANGLE PROJECTION DO NOT SCALE DRAWING	1004-1212	
Material	Flexible PVC		DESIGNER: D. Brady	
Installation Torque	60" Lbs.		CHECKER:	
Conforms to ASTM	D5926, C1173		DATE: 2/1/2007	
Box Quantity	5	SCALE not to scale		
Clamps used	300 Series	SHEET 1 OF 1		